




EMERGENCY RECALL ORDER



The Pipeline and Hazardous Materials Safety Administration issued an emergency recall of 55,000+ propane cylinders manufactured by The Lite Cylinder Company.

These cylinders may leak flammable gas or suddenly rupture.

The full recall order is available at:
<http://go.usa.gov/bbyV>



The affected cylinders may be marked in the location indicated above with any of the following numbers: M5729, DOT-SP 14562, DOT-SP 13957, DOT-SP 13105 (Only if manufactured by The Lite Cylinder Company. Cylinders manufactured by **Composite Scandinavia** [M0408] and marked with this number **are not** subject to the recall).

In the absence of instructions from Lite Cylinder, PHMSA advises anyone possessing one of these cylinders to:

- Stop using the cylinder(s)
- Close the valve(s)
- Safely disconnect the cylinders once the valves are closed
- Store the cylinder(s) in a space that is well ventilated and not enclosed
- Protect the cylinder(s) from heat and keep away from all heat sources

WARNING: ATTEMPTS TO EMPTY THE CYLINDER OR REMOVE THE CYLINDER VALVE BY UNQUALIFIED PERSONS MAY LEAD TO SERIOUS INJURY OR DEATH